



AUSTIN WATER UTILITY
Utility Development Services Division
625 East 10th Street, Suite 515
Austin, Texas 78701
(512) 972-0207 fax: (512) 972-0251



LICENSE TO OPERATE AN ON-SITE SEWAGE FACILITY

DATE: November 10, 2004
SITE ADDRESS: 8811 FM Rd. 969, Austin, Texas 78724
LEGAL DESCRIPTION: LOT 1, PITTS FAMILY SUBD.
OWNER'S NAME: PITTS CONSTRUCTION INC.
LAKE PROPERTY (YES/NO): NO
WATER SOURCE: City of Austin
TYPE OF STRUCTURE: Non-Residential
SIZE: Modular Office Building / 240 gpd

UNIQUE #: 410418

FACILITY SPECIFICATIONS

1. One 1000-gallon dual compartment pre-cast concrete septic tank
2. One 500-gallon single compartment pre-cast concrete pump tank with a submersible effluent pump (capable of delivering 12.2 gpm at 9.7 ft of total head)
3. Two low pressure dosed drainfields of 960 square feet of absorption area (240 ft of lateral lines).

MAINTAINANCE CONTRACT REQUIRED (YES/NO): NO
DESIGNER: Herndon C. Bailey, Jr., P.E.
INSTALLER: Bill Kayman, OSII

The above referenced on-site sewage facility has been inspected by the Austin Water Utility for compliance with the City of Austin Ordinance No. 990211-E, and, based on information provided in the application, has been found to comply with the requirements of that Ordinance. This License is transferable upon change of ownership.

Note: This certification does not extend to the materials, workmanship or fabrication of the on-site sewage facility so as to express or imply to the owner or installer of the facility any warranty by or rights against the City of Austin or any of its agencies, as to the quality or durability of the facility nor compliance with the owner's individual specifications and requirements but solely relates to the facility meeting the requirements of the City of Austin in effect as of this date.

APPROVED: _____

Sydney M. Mun, P.E.

DATE: 11/10/04